

Sada Services Pty Limited.

POELA Act 2011 Monitoring Data - 2014

Glenlee Coal Preparation Plant, Narellan, NSW 2567

EPA Licence Number 1596, held by Sada Services Pty Limited

Record Updated on: 15/11/2017

Water Monitoring

Wet Weather discharge via the overflow weir to the Nepean River from No.2 reclaimed water pond labelled as the Licenced Discharge Point.

Date Sampled	Date report received	Date published	pH Unit	Salinity g/L	BoD mg/L	Total Suspended Solids (mg/l)
Licence Limits			6.5 - 8.5	monitor only	max. 20	max. 30
Results						
4/06/2013	12/06/2013	26/06/2013	7.9	< 0.2	6	< 5
31/07/2013	5/08/2013	15/08/2013	7.8	0.3	< 2	< 5
18/09/2013	25/09/2013	15/10/2013	8.3	0.4	< 2	2
13/11/2013	20/11/2013	28/11/2013	8.0	0.5	< 2	13
11/12/2013	18/12/2013	20/12/2013	7.8	0.6	< 2	9
15/01/2014	23/01/2014	29/01/2014	8.1	0.7	< 2	12
12/03/2014	21/03/2014	27/03/2014	8.1	0.8	< 2	9
26/03/2014	2/04/2014	15/04/2014	8.2	0.9	< 2	13
11/06/2014	18/06/2014	20/06/2014	8.1	< 0.2	< 2	< 5
9/07/2014	16/07/2014	18/07/2014	8.2	< 0.2	< 2	< 5
18/08/2014	28/08/2014	28/08/2014	8.2	< 0.2	< 2	28
27/08/2014	3/09/2014	3/09/2014	7.8	0.3	< 2	< 5
15/10/2014	22/10/2014	22/10/2014	7.5	0.6	< 2	13
16/12/2014	23/12/2014	23/01/2015	8.0	0.7	11	< 2
14/01/2015	23/01/2015	23/01/2015	8.3	0.7	9	4
1/05/2015	11/05/2015	22/05/2015	7.5	<0.2	< 5	< 2
27/05/2015	3/06/2015	26/06/2015	7.6	0.6	< 5	< 2
24/06/2015	3/07/2015	17/07/2015	7.6	0.7	7	4
12/08/2015	19/08/2015	21/08/2015	7.7	0.8	< 5	< 2
20/10/2015	2/11/2015	13/11/2015	8.2	N/A	N/A	< 2
11/01/2016	19/01/2016	28/01/2016	8.2	<0.2	< 5	< 2
29/01/2016	8/02/2016	8/02/2016	8.4	<2.0	10	<2
6/06/2016	14/06/2016	27/06/2016	7.6	0.14	<2	389
20/06/2016	27/06/2016	27/06/2016	7.7	0.2	2	11
3/08/2016	12/08/2016	30/08/2016	7.5	0.6	2	<5
17/03/2017	24/03/2017	28/03/2017	8.2	0.3	12	<2
5/05/2017	12/05/2017	16/06/2017	8.3	0.4	<5	<2
8/06/2017	15/06/2017	16/06/2017	7.9	0.5	10	5
19/06/2017	28/06/2017	13/07/2017	7.8	0.59	6	5
5/07/2017	12/07/2017	13/07/2017	7.9	0.7	11	<2
26/07/2017	1/08/2017	8/08/2017	8.5	0.7	<5	8
6/11/2017	13/11/2017	15/11/2017	8.0	0.6	5	<2

Note: values noted as " < # " means that the levels were below laboratory detection limits